


# CAST IN PLACE PENETRATION

FOR 2" PIPE AND LARGER  
CONCRETE ON CORRUGATED METAL DECK  
FOR FLOORS



Pipe Penetration	Size	Part No.	Description	Price	Unit Total
EMT/PVC	2"	P2543H-G A02214	2" Sleeve Coupling 2" Riser Clamp	6.50 2.95	9.45
EMT/PVC	2½"	P3843H A03212	2½" Sleeve Coupling 2½" Riser Clamp	11.00 3.85	14.85
EMT/PVC	3"	P3543H-G A03214	3" Sleeve Coupling 3" Riser Clamp	9.15 3.30	12.45
EMT	3½"	P4843H A03312	3½" Sleeve Coupling 3½" Riser Clamp	13.30 5.10	18.40
EMT	4"	P4543H-G A04214	4" Sleeve Coupling 4" Riser Clamp	11.45 4.15	15.60
EMT	5"	P6843H A05214	5" Sleeve Coupling 5" Riser Clamp	23.15 6.60	29.75
EMT	6"	P6543H-B A06214	6" Sleeve Coupling 6" Riser Clamp	17.40 6.75	24.15

Important: After risers clamp part number, add EMT or P for PVC



W.H. Directory Reference 97 Edition  
Firestop Device  
W.H. Design No. PS/PHV 120-05  
F Rating 2 Hrs.



**PROSET**<sup>®</sup>  
**SYSTEMS**  
FIRESTOP PENETRATOR<sup>™</sup>

DATE :  
12-11-19  
DRG. NO. :  
E-1014-C